

SECTION 2150 – EROSION AND SEDIMENT CONTROL

CITY OF LEE’S SUMMIT, MISSOURI STANDARD SPECIFICATIONS

The City of Lee’s Summit hereby adopts Section 2150 of the Kansas City Metropolitan Chapter of APWA Construction and Material Specifications, current edition. The following additions, deletions and/or revisions are adopted as a part of Section 2150 for use within Lee’s Summit. Text in bold italics indicates revisions or additions to the APWA standard.

2154.5.A (Silt Fence) Materials, Construction Requirements, and Maintenance:

ADD the following:

- 1. Silt fence typically should not be used in swales, drainage-ways, channels and other conduits of concentrated stormwater flow and will only be considered on a case by case basis.*
- 2. Silt fence typically should not be used to direct or divert water and will only be considered on a case by case basis.*